

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHIECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÈQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod Lisem 129, 171 02 Praha 8 - Troja

LICENCE FOR HAR CONFORMITY MARK

No.: 6130003

Licensee: nkt cables Vrchlabí s.r.o., člen skupiny NKT
Českých bratří 509, 543 14 Vrchlabí, Czech Republic

Manufacturer: nkt cables Vrchlabí s.r.o., člen skupiny NKT
Českých bratří 509, 543 14 Vrchlabí, Czech Republic

Factory: nkt cables Vrchlabí s.r.o., člen skupiny NKT
Českých bratří 509, 543 14 Vrchlabí, Czech Republic

Name of Product: Flexible cables with thermoplastic PVC insulation

Type of product: H05VV-F

Rating: (2 - 5) x (0,75 - 4) mm²; 300/500 V

Trade Mark:

Electrotechnical Testing Institute is granting a licence for using the following mark



or identification thread (black – 1 cm, red – 3 cm, yellow – 11 cm), (code 22).

One of these marks may be used for the product specified in this certificate within validity of the Agreement on the use of the HAR Mark by implementing all the rules stated in the Agreement.

The right to use the above mentioned mark for the product is based on:

- Test report No.: 300325-01/01 of: 29.01.2013

A sample of the product was tested and found to be in conformity with:
EN 50525-2-11:2011

- certified quality system according to 205002-01 of 31.10.2012 performed by EZÚ
- the General Agreement on the use of the HAR Mark No. 1810 and the agreement No. 300325-01 concluded between the ordering firm and the Electrotechnical Testing Institute
- compliance with the certification scheme „HAR“

Certificate supersedes: -

This certificate/licence is issued according to the rules of the HAR Agreement, wherein the certificate/licence issued by any certification body adhering to HAR Agreement has the same worth and validity in all the other certification bodies' countries.

8.2.2013

Prague

Miroslav Sedláček
Head of Certification Body



300325-01